

## Spratton Folk Festival

Use of generators on the festival site and camping ground is subject to the following conditions: -

- Only 110V / 240 V output generators permitted
- Use of any generator is entirely at discretion of SFF organisers
- Generators must be used in well-ventilated locations sited away from others so that noise and fumes are not a nuisance.
- Generators must be silent running and not used after 2300hrs.
- Generator and ancillary equipment must be in good order ideally accompanied by proof of inspection by competent person within the previous 6 months or be newly purchased.
- All moving parts / hot surfaces must be suitably guarded.
- All electrical connections must be waterproof.
- All cables must be protected from damage.
- Electrical supply must be protected by RCD, which should be tested daily.
- Amount of liquids must be kept to a minimum and stored in a secure location.
- All substantial amounts of liquids to be stored in bunded areas - constructed to contain spills
- Installation will be subject to inspection by event safety adviser
- Any faults must be rectified immediately by competent person.
- A suitable fire extinguisher [e.g. powder] must be available.